





NOTE: DIMENSIONS IN [ ] ARE INCH EQUIVALENTS.

REV	DATE	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
-	05DEC2022	NEW DRAWING	AKH
A	11JAN2023	SEE SHEET 2 AND 5	AKH
B	14FEB2023	SEE SHEET 4 & 5	AKH

UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: N/A		DO NOT SCALE. THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001. REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.	
THIRD ANGLE PROJECTION 		<b>KOHLER.</b>	
MAJOR  = 0	CRITICAL  = 0	SCALE: 0.40	SHEET SIZE: B
CHARACTERISTICS COMPLY WITH KPS-80022		SHEET: 1 OF 5	
DRAWN: AKH	DATE: 05DEC2022	TITLE: <b>DIMENSION PRINT, 26RCA</b>	
APPROVED: SEE PLM SYSTEM		DWG NO.: <b>ADV-9919</b>	



AIR CLEANER

BREATHER TUBE HEATER (OPTIONAL)

OIL FILTER

OIL DIPSTICK

OIL PRESSURE SWITCH COVER (OPTIONAL)

ENGINE SHUTDOWN SWITCH

CARB HEATER (OPTIONAL)


OIL FILL

OIL DRAIN VALVE

OIL HEATER (OPTIONAL)

EXHAUST AIR OUTLET


REV	DATE	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
-	05DEC2022	NEW DRAWING	AKH
A	11JAN2023	(D-7) OIL PRESSURE SWITCH COVER (OPTIONAL) WAS OIL PRESSURE SWITCH (OPTIONAL); SEE SHEET 5	AKH
B	14FEB2023	SEE SHEET 4 & 5	AKH

UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: N/A	
THIRD ANGLE PROJECTION 	
MAJOR CRITICAL	0 0
CHARACTERISTICS COMPLY WITH KPS-80022	
DRAWN: AKH	DATE: 05DEC2022
APPROVED: SEE PLM SYSTEM	

DO NOT SCALE. THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001. REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.		
<b>KOHLER.</b>		
SCALE: 0.40	SHEET SIZE: B	SHEET: 2 OF 5
TITLE: <b>DIMENSION PRINT, 26RCA</b>		
DWG NO.: <b>ADV-9919</b>		



AIR INLET



OIL DRAIN HOSE

BATTERY HEATER  
(OPTIONAL)

BATTERY LOCATION  
(BATTERY NOT INCLUDED)

BATTERY CABLES  
(INCLUDED)

CUSTOMER  
CONNECTION  
BLOCK

FUEL REGULATOR  
HEATER PAD  
(OPTIONAL)

LOAD CIRCUIT BREAKER

CONTROLLER

USB PORT

REV	DATE	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
-	05DEC2022	NEW DRAWING	AKH
A	11JAN2023	SEE SHEET 2 AND 5	AKH
B	14FEB2023	SEE SHEET 4 & 5	AKH

26RCA

UNLESS OTHERWISE SPECIFIED:  
ALL DIMENSIONS IN MILLIMETERS  
GENERAL TOLERANCES: N/A

THIRD ANGLE PROJECTION

MAJOR = 0  
CRITICAL = 0  
CHARACTERISTICS COMPLY WITH  
KPS-80022

DRAWN: AKH      DATE: 05DEC2022  
APPROVED: SEE PLM SYSTEM


DO NOT SCALE.  
THIS ASSEMBLY OR PART MUST  
COMPLY WITH PEP-RML-001.  
REFERENCE CAD MODEL FOR  
UNSPECIFIED DIMENSIONS.

**KOHLER.**

SCALE: 0.40    SHEET SIZE: B    SHEET: 3 OF 5

TITLE:  
**DIMENSION PRINT, 26RCA**

DWG NO.: **ADV-9919**




NOTE:  
⚠ THE RECOMMENDED DISTANCE FROM A STRUCTURE IS DEPENDENT ON STATE AND LOCAL CODES. PRODUCT HAS BEEN DEMONSTRATED IN ACCORDANCE WITH NFPA 37 SECTION 4.1.4 BY A THIRD PARTY TEST FACILITY TO THE DIMENSIONS SHOWN.

ACCEPTABLE

- 1) EXHAUST IS AIMED AWAY OR PARALLEL TO STRUCTURE.
- 2) EXHAUST IS NOT DIRECTED AT PLAY AREAS, PATIOS OR OTHER AREAS WHERE PEOPLE CONGREGATE.
- 3) THE NEAREST WINDOW, VENT, DOOR OR SIMILAR STRUCTURE OPENING IS AT LEAST 5 FEET FROM THE EXHAUST END OF THE SET.
- 4) SET HAS PROPER OFFSET FROM STRUCTURE.
- 5) WINDOWS & DOORS ON ADJACENT WALLS ARE CLOSED.
- 6) FURNACE AND OTHER SIMILAR INTAKES ARE AT LEAST 10 FEET FROM EXHAUST END OF SET.
- 7) WEED BARRIER AND 3 INCH THICK GRAVEL BASE OR CONCRETE PAD LOCATED TO PREVENT GRASS & WEEDS FROM GROWING TOO CLOSE TO THE SET.
- 8) NO PLANTS, SHRUBS OR OTHER COMBUSTIBLES ALLOWED IN CLEARANCE AREA. (MINIMUM 4 FT. FROM EXHAUST END).
- 9) REFER TO OWNERS MANUAL FOR OTHER INSTALLATION CONSTRAINTS.
- 10) NO PLANTS, SHRUBS, OR OTHER COMBUSTIBLES ALLOWED WITHIN 30" OF AIR INTAKE.
- 11) MUST MAINTAIN A MINIMUM OF 3 FEET CLEARANCE FROM SERVICE DOOR ENTRANCE.
- 12) OVERHANGS AND AWNINGS MUST BE A MINIMUM OF 5 FEET FROM GENSET.

REV	DATE	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
-	05DEC2022	NEW DRAWING	AKH
A	11JAN2023	SEE SHEET 2 AND 5	AKH
B	14FEB2023	(B-2) 3 FEET CLEARANCE WAS 5 FEET CLEARANCE; SEE SHEET 5	AKH

UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: N/A		DO NOT SCALE. THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001. REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.		
THIRD ANGLE PROJECTION 		<b>KOHLER.</b>		
MAJOR ♂ = 0 CRITICAL ♀ = 0 CHARACTERISTICS COMPLY WITH KPS-80022		SCALE: 0.40	SHEET SIZE: B	SHEET: 4 OF 5
DRAWN: AKH APPROVED: SEE PLM SYSTEM		TITLE: <b>DIMENSION PRINT, 26RCA</b>		
DATE: 05DEC2022		DWG NO.: <b>ADV-9919</b>		

26RCA  
SINGLE UNIT  
CONFIGURATION

